



# MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

## TEST - REPORT

Not for legal use

Ref. No. & Date :- No.GMSH/40A/2024-25/1029 dated: 25.03.2025  
Issued to :- The Headmaster  
:- Govt Model High School  
:- Sector - 40,A, Chandigarh  
Quantity of sample :- Approximate 1200 ml .  
Date of Collection :- 29-03-2025  
Client reference :- Sample Collected by Laboratory Staff  
Packing of sample :- Sample filled in P.P. and Glass Bottle  
Source of sample :- from School tap of Govt Model High School  
Sector - 40,A, Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.77
2	Odour	Agreeable	-----	Agreeable
3	Taste	Agreeable	-----	Agreeable
4	Turbidity	< 1.0	N.T.U.	0.7
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO <sub>3</sub> )	< 200	mg/l	78
7	Total Hardness (as CaCO <sub>3</sub> )	< 200	mg/l	70
8	Chloride (as Cl )	< 250	mg/l	04
9	Free & Saline Ammonia	NIL	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	123
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received videreceipt No.03/2024-25/240592, dated 26.03.2025, Amount Rs.3300/-

**Note: Water is fit for drinking.**

Lab No.- MCPHL/25/ .10.70.....


Dated:- 02.04.2025


  
Chemist  
M.C.P.H. Laboratory  
Chandigarh

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh  
Dated :-02.04.2025

Endst No. MCPH/25/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh  
For Information Please.

  
Chemist  
M.C.P.H. Laboratory  
Chandigarh

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh