



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT
Not for legal use

Date : 22.05.2026

Lab No. : MCPHL/26/1A28

		Sample Details	Date & Time
Ref. No.	GMHS-40(A)2026-27/283	Collected By	Laboratory Staff
Dated	18.05.2026	Collection Date	19.05.2026 at 9:15a.m
Issued to	The Headmaster Govt. Model High School Sector - 40(A), Chandigarh.	Received at Lab	09:25a.m.
Location	From School tap of Govt. Model High School Sector - 40(A), Chandigarh.		
Packing	Polypropylene and glass bottle		

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.65
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	<1	N.T.U.	0.8
5	Total Dissolved Solids	<500	mg/l	163
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	112
8	Total Hardness (as CaCO ₃)	<200	mg/l	108
9	Chlorides (as Cl)	<250	mg/l	06
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 05/2026-27/320056, dated 18.05.2026, amount Rs.-3300/-

Note:- Water sample is found "POTABLE"

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/26/-----

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.

Dated : 22.05.2026

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT

MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)

(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)
(NO OBJECTION CERTIFICATE)

No. MOH/Supdt.Admn/NOC/2026/ 7972

Dated:- 20/7/26

It is certified that an inspection team headed by Sh. Vijay Kumar, Chief Sanitary Inspector from Office of Medical Officer of Health, Municipal Corporation Chandigarh inspected the Govt Model High School Sector 40 A, Chandigarh on 09.07.2026 and mentioned in inspection report that the Govt Model High School Sector 40 A, Chandigarh is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt.

The above Certificate is valid for a period of One-year w.e.f 22.05.2026 (i.e. Water Sampling Date)


Medical Officer of Health
Municipal Corporation
Chandigarh

To
Govt Model High School
Sector 40 A,
Chandigarh